

PLAN HOURS.

PLAN ADJUSTED HOURS

SYST Nr	SYSTEM NAME	Desn		Draft	Prog		PrMgr mgmt PM	Tech		Shop		Electrician					Mechanic			
		syst DS	mat'l DM		syst PS	panel PP		softw TS	hardw TH	eshop SE	mshop SM	cond EC	wire EW	dev ED	term ET	start ES	pipe MP	dev MD	term MT	start MS
001	UNIT HEATERS	2	1	4	1	-1	3	0	1	0	0	20	4	5	2	1	0	0	0	0
002	AHU A1 - 1	6	22	18	7	21	34	21	22	31	0	76	15	26	10	5	15	10	2	1
003	AHU A1 - 2	4	22	22	4	21	47	21	37	31	0	60	22	25	10	5	19	10	2	1
004	AHU A1 - 6	6	22	18	7	20	33	20	22	31	0	51	13	26	10	5	17	10	2	1
005	AHU A1 - 3	4	15	15	4	25	33	25	23	31	0	95	28	27	10	5	62	7	2	1
006	AHU A1 - 4	4	15	15	4	23	32	23	23	31	0	93	21	26	10	5	41	7	2	1
007	AHU A1 - 5	6	13	18	3	10	26	10	20	22	0	43	9	19	7	4	0	13	1	1
008	AHU A1 - 7	6	11	11	2	12	35	12	12	22	0	17	5	13	8	4	11	9	1	1
009	FAN POWER BOXES	5	2	9	2	1	2	0	3	0	0	5	2	8	5	3	0	0	0	0
010	VAV BOXES	3	3	6	1	2	3	0	3	0	0	11	5	12	8	4	0	0	0	0
011	MER VENTILATION	3	5	4	2	6	5	7	5	0	0	25	4	10	5	3	0	0	0	0
012	U NET	0	1	1	0	0	16	1	15	4	0	0	1	3	3	1	0	0	0	0
013	ELECT ROOM VENTILATI	3	3	4	2	6	5	7	5	0	0	25	4	8	4	3	0	0	0	0
014	ELEV MER (EF-AM-3)	3	1	3	2	1	1	1	1	2	0	6	1	2	1	0	0	0	0	0
015	TOILET EF (EF-AM-1 & 2)	3	1	4	2	2	2	3	2	4	0	8	2	2	1	1	0	0	0	0
146	HALL DIFFUSERS (AHU A1	3	2	6	1	3	9	1	15	0	0	75	5	4	0	0	0	0	0	0
147	HALL DIFFUSERS (AHU A1	1	2	4	0	3	9	1	15	0	0	75	5	4	0	0	0	0	0	0
A - LEVEL 1 AREA A1 & 2		62	141	162	44	155	295	153	224	209	0	685	146	220	94	49	165	66	12	7
016	FAN POWERED BOXES	1	3	3	0	1	2	0	4	0	0	6	2	10	7	4	0	0	0	0
017	FAN COILS	3	2	4	2	1	2	0	3	0	0	10	1	4	3	2	0	0	0	0
018	U NET	0	1	1	0	0	32	1	29	4	0	0	2	3	3	1	0	0	0	0
019	AHU A2 - 1	4	12	10	4	10	33	10	11	22	0	21	6	12	7	3	8	11	1	1
020	AHU A2 - 2	2	12	7	3	10	31	10	11	22	0	21	6	12	7	3	8	11	1	1
021	AHU A2 - 3	2	12	7	3	10	31	10	11	22	0	21	6	12	7	3	8	11	1	1
022	ELECT ROOM VENT	3	2	3	2	0	4	0	3	4	0	19	2	3	2	1	0	0	0	0
159	PORTABLE REMOTE SENS	2	5	7	1	6	16	5	9	7	0	0	7	30	6	3	0	0	0	0
B - LEVEL 2 AREA A1 & 2		17	49	42	15	38	151	36	81	81	0	98	32	86	42	20	24	33	3	3
023	FAN POWERED BOXES	1	7	5	0	3	6	0	10	0	0	12	5	23	15	9	0	0	0	0
024	FAN COILS	1	2	2	0	1	2	0	3	0	0	10	1	4	3	2	0	0	0	0
025	ELECT RM VENT (DDC)	3	2	3	2	0	4	0	3	4	0	19	2	3	2	1	0	0	0	0
026	AHU A3 - 1	2	12	7	3	10	30	10	11	22	0	21	6	12	7	3	8	11	1	1
027	AHU A3 - 2	2	12	7	3	10	30	10	11	22	0	21	6	12	7	3	8	11	1	1
C - LEVEL 3 AREA A1 & 2		9	35	24	8	24	72	20	38	48	0	83	20	54	34	18	16	22	2	2
028	SMK EXH (EF A3 - 1/2/3)	3	3	4	1	2	19	3	1	0	0	0	0	2	1	1	41	13	7	3
D - LEVEL 4 AREA A1 & 2		3	3	4	1	2	19	3	1	0	0	0	0	2	1	1	41	13	7	3
029	AHU B1 - 1	4	22	15	4	25	33	24	23	31	0	94	14	30	11	6	15	10	2	1